

## 3/71

41 29 02 73 44 13

COUNTY OFFICE BUILDING - CARMEL, NEW YORK

P105

RECEIVED

JUL 12 1982

PUTNAM COUNTY  
DEPT. OF HEALTH

930 5

OWNER	NAME <u>Hal Barrett</u> <u>M &amp; H Custom Homes</u> <i>Pica, Peter</i>		ADDRESS <u>Deacon Smith Hill Rd. Holmes, NY</u>		JUL 12 19	
LOCATION OF WELL	(No. & Street) <u><del>Ponderosa Rd.</del> Lacross Rd.</u>		(Town) <u>Kent</u>		(Lot Number) <u>PUTNAM CO</u> <u>DEPT. OF HE</u> <u>930</u>	
PROPOSED USE OF WELL	<input checked="" type="checkbox"/> DOMESTIC	<input type="checkbox"/> BUSINESS ESTABLISHMENT	<input type="checkbox"/> FARM	<input type="checkbox"/> TEST WELL		
	<input type="checkbox"/> PUBLIC SUPPLY	<input type="checkbox"/> INDUSTRIAL	<input type="checkbox"/> AIR CONDITIONING	<input type="checkbox"/> OTHER (Specify)		
DRILLING EQUIPMENT	<input type="checkbox"/> ROTARY	<input checked="" type="checkbox"/> COMPRESSED AIR PERCUSSION	<input type="checkbox"/> CABLE PERCUSSION	<input type="checkbox"/> OTHER (Specify)		
CASING DETAILS	LENGTH (feet) <u>24</u>	DIAMETER (inches) <u>6</u>	WEIGHT PER FOOT <u>19</u>	<input checked="" type="checkbox"/> THREADED <input type="checkbox"/> WELDED	DRIVE SHOE <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	WAS CASING GROUTED? <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
YIELD TEST	<input type="checkbox"/> BAILED	<input type="checkbox"/> PUMPED	<input checked="" type="checkbox"/> COMPRESSED AIR	HOURS	G.P.M.	YIELD (G.P.M.) <u>15</u>
WATER LEVEL	MEASURE FROM <u>LAND SURFACE</u> - STATIC (Specify feet)		DURING YIELD TEST (feet) <u>Total drawdown</u>		Depth of Completed Well in feet below Land surface: <u>225</u>	
SCREEN DETAILS	MAKE				LENGTH OPEN TO AQUIFER (feet)	
	SLOT SIZE	DIAMETER (inches)	IF GRAVEL PACKED:	Diameter of well including gravel pack (inches):	GRAVEL SIZE (inches)	FROM (feet) TO (feet)

[illegible]

DATE WELL COMPLETED

DATE OF REPORT

WELL DRILLER (Signature)

July 2 1982

DATE OF REPORT  
July 2, 1982

Wm. S. Boyd  
Boyd Artesian Well Co.